



Ref. Certif. No.

DE 2-044074-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Power Conversion System
Name and address of the applicant	GoodWe Technologies Co., Ltd. No.90 Zijin Rd., New District 215011 Suzhou, P.R. China
Name and address of the manufacturer	GoodWe Technologies Co., Ltd. No.90 Zijin Rd., New District 215011 Suzhou, P.R. China
Name and address of the factory	GoodWe (GuangDe) Power Supply Technology Co., Ltd No.8, Dongting Rd., Guangde Economic Development Zone, Anhui, P.R. China
Ratings and principal characteristics	Input : Vmax Battery [Vdc]: 1000 Output: Rated Input/Output Voltage [Vac]: 3W+N+PE, 400/380 Rated Input/Output Power [kW]: 100, 125, 100, 125
Trademark (if any)	GOODWE (logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) GW100K-PCS-N-G10 , 2) GW125K-PCS-N-G10 , 3) GW100K-PCS-N-G11 , 4) GW125K-PCS-N-G11
Additional information (if necessary may also be reported on page 2)	For model differences, refer to test report Re-issue of DE 2-044074 dated 2025-03-17, due to first modification.
A sample of the product was tested and found to be in conformity with	IEC 62477-1:2022
As shown in the Test Report Ref. No. which forms part of this Certificate	CN254HV5 002

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland LGA Products GmbH  
Tillystr. 2, 90431 Nürnberg, Germany  
Phone + 49 221 806-1371  
Fax + 49 221 806-3935  
Mail: cert-validity@de.tuv.com  
Web : www.tuv.com

Date: 2025-05-14

Signature:

A. Chen