



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA200591

Certificate Holder: Jiangsu Goodwe Power Supply Technology Co., Ltd.
No. 90 ZiJin Road, New District,
Suzhou, 215011,
P.R. China

Regulatory Definition: Non-Prescribed
Product Description: Grid-tied photovoltaic Inverter
Trade Name: GOODWE
Model No.: GW3000-XS
Markings: Input: MPPT Voltage range: 50-450Vdc, Max 500Vdc,
Max 12.5A, Isc PV: 15.6A
Output: 220/230V~ 50/60Hz, Max 14.3A,
3000W, Max 3300VA
Class I, -25°C to +60°C, IP65
Standard: IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0
AS/NZS 4777.2:2015
Conditions: Nil
Certification Mark: RCM and SAA200591
Date First Registered: 28 April 2020
Date of Expiry: 28 April 2025

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 28-04-20 200591/1

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA200591

Date of Issue: 28 April 2020

Regulatory Definition: Non-Prescribed

Product Description: Grid-tied photovoltaic Inverter

General Modification:

Hardware Version: Inverter board: 290-10092, Power board: 29010091

Software Version: V1.00.08

| Additional Models | Trade Name | Rating |
|-------------------|------------|---|
| GW700-XS | GOODWE | Input: MPPT Voltage range: 50-450Vdc, Max 500Vdc, Max 12.5A, Isc PV: 15.6A Output: 230V~ 50Hz, Max 3.5A, 700W, Max 800VA |
| GW1000-XS | GOODWE | Input: MPPT Voltage range: 50-450Vdc, Max 500Vdc, Max 12.5A, Isc PV: 15.6A Output: 230V~ 50Hz, Max 4.8A, 1000W, Max 1100VA |
| GW1500-XS | GOODWE | Input: MPPT Voltage range: 50-450Vdc, Max 500Vdc, Max 12.5A, Isc PV: 15.6A Output: 230V~ 50Hz, Max 7.2A, 1500W, Max 1650VA |
| GW2000-XS | GOODWE | Input: MPPT Voltage range: 50-450Vdc, Max 500Vdc, Max 12.5A, Isc PV: 15.6A Output: 230V~ 50Hz, Max 9.6A, 2000W, Max 2200VA |
| GW2500-XS | GOODWE | Input: MPPT Voltage range: 50-450Vdc, Max 500Vdc, Max 12.5A, Isc PV: 15.6A Output: 230V~ 50Hz, Max 12A, 2500W, Max 2750VA |

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 28-04-20 200591/2